

TECHNICAL INSULATION

ProRox[®] WM 950

with WR-Tech

ProRox WM 950 is a lightly bonded stone wool insulation mat stitched on galvanized wire mesh with galvanized wire. Stainless steel mesh and binding wire (SW), and/or reinforced aluminium foil (ALU) facing are available upon request. The wired mats are produced with an innovative water-repellent binder, known as WR-Tech[™], to mitigate the risk of corrosion under insulation (CUI). WR-Tech ensures our stone wool maintains its superior water repellency even at elevated operating temperatures within the CUI range, while preserving its excellent thermal performance in use.



Application

The wired mat is suitable for the thermal and acoustic insulation of industrial installations exposed to the environment, such as outdoor industrial pipework and equipment at petrochemical plants and refineries.

Product properties in accordance with ASTM C592-16

roduct properties in accordance with ASTM C372-10								
Performance								Norms
T _m (°F)	100	200	300	400	500	600	700	ASTM C177
λ (BTU.in/hr.ft ² .°F)	0.25	0.30	0.35	0.42	0.49	0.58	0.68	
T _m (°C)	38	93	149	204	260	316	371	
λ (W/mK)	0.036	0.043	0.051	0.060	0.071	0.084	0.098	
1,200 °F (649 °C)								ASTM C447
≤ 2% @ 1,200 °F (649 °C)								ASTM C356
Flame spread index \leq 25; Smoke development index \leq 50								ASTM E84 (UL723)
Non combustible								IMO 2010 FTPC
5.0 lb/ft³ (80 kg/m³)								ASTM C167
Evaluation on external stress corrosion cracking tendency of austenitic stainless steel = Pass								ASTM C692 / ASTM C795
Chemical analysis for Cl $^{\rm \cdot}$, Fl $^{\rm \cdot}$, Na $^{\rm +}$, SiO $_4^4$ within acceptable limits according ASTM C795								ASTM C871 / ASTM C795
≤ 0.04 lb/ft² (≤ 0.2 kg/m²) after 24hrs. Pre-heating at 482°F (250°C)								EN 1609 / EN ISO 29767
< 1% weight								ASTM C1104
Free form substances (e.g. silicone oil) that might impair surface wetting								VW 3.10.7
	λ (BTU.in/hr.ft².°F) T _m (°C) λ (W/mK) Fla Ev Chemical analysis ≤ 0.04	$\frac{\lambda \text{ (BTU.in/hr.ft2.°F)}}{T_m (°C)} 0.25$ $\frac{T_m (°C)}{38}$ $\lambda (W/mK) 0.036$ Flame sprea Evaluation of Chemical analysis for Cl ⁻ , Fl $\leq 0.04 \text{ lb/ft}^2 (\leq 0.04)$	$T_m (°F) 100 200 λ (BTU.in/hr.ft2.°F) 0.25 0.30 T_m (°C) 38 93 λ (W/mK) 0.036 0.043 I,2 ≤ 2% 0 Flame spread index ≤ 2 Not Statement of austenit Chemical analysis for Cl-, Fl-, Na+, Sic ≤ 0.04 lb/ft2 (≤ 0.2 kg/m2) ar$	$\begin{array}{c c c c c c c } T_{m} (^{\circ} F) & 100 & 200 & 300 \\ \hline \lambda (BTU.in/hr.ft^{2}.^{\circ} F) & 0.25 & 0.30 & 0.35 \\ \hline T_{m} (^{\circ} C) & 38 & 93 & 149 \\ \hline \lambda (W/mK) & 0.036 & 0.043 & 0.051 \\ \hline 1,200 ^{\circ} F (649 \\ \leq 2\% @ 1,200 ^{\circ} F (649 \\ \leq \% \oplus$	$\begin{array}{c c c c c c c } T_{m} (\ensuremath{^{\circ}} F) & 100 & 200 & 300 & 400 \\ \lambda (BTU.in/hr.ft^{2}.\ensuremath{^{\circ}} F) & 0.25 & 0.30 & 0.35 & 0.42 \\ \hline T_{m} (\ensuremath{^{\circ}} C) & 38 & 93 & 149 & 204 \\ \lambda (W/mK) & 0.036 & 0.043 & 0.051 & 0.060 \\ & & & & & & & & & & & & & & & & & & $	Tm (°F) 100 200 300 400 500 λ (BTU.in/hr.ft².°F) 0.25 0.30 0.35 0.42 0.49 Tm (°C) 38 93 149 204 260 λ (W/mK) 0.036 0.043 0.051 0.060 0.071 1,200 °F (649 °C) Flame spread index < 25; Smoke development index <	$\begin{array}{c c c c c c } T_m(``F) & 100 & 200 & 300 & 400 & 500 & 600 \\ \hline λ (BTU.in/hr.ft^2.^F) & 0.25 & 0.30 & 0.35 & 0.42 & 0.49 & 0.58 \\ \hline $T_m(``C) & 38 & 93 & 149 & 204 & 260 & 316 \\ \hline λ (W/mK) & 0.036 & 0.043 & 0.051 & 0.060 & 0.071 & 0.084 \\ \hline $1,200 ``F$ (649 ``C) \\ \hline $1,2$	$\begin{array}{c c c c c c } T_m (``F) & 100 & 200 & 300 & 400 & 500 & 600 & 700 \\ \hline λ (BTU.in/hr.ft².`F) & 0.25 & 0.30 & 0.35 & 0.42 & 0.49 & 0.58 & 0.68 \\ \hline $T_m (``C) & 38 & 93 & 149 & 204 & 260 & 316 & 371 \\ \hline λ (W/mK) & 0.036 & 0.043 & 0.051 & 0.060 & 0.071 & 0.084 & 0.098 \\ \hline $1,200 ``F (649 ``C) & $$$ - $$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$ - $$$$$$$

Compliance

- ProRox WM 950 fully complies with the requirements as set by the internationally recognized standards like EN 14303, ASTM C592 Type III, ASTM C795, VDI 2055, VDI 2055 and CINI 2.2.02.
- Above product declarations are also applicable for other available product variances and/or optional facings.
- ROCKWOOL stone wool insulation is made from volcanic rock and is not classified as a hazardous substance in accordance with Note Q, regulation (EC) No. 1272/2008.

As ROCKWOOL has no control over insulation design and workmanship, accessory materials or applications conditions, ROCKWOOL does not warranty the performance or result of any installation containing ROCKWOOL products. ROCKWOOL's overall liability and the remedies available are limited by the general terms and conditions of sale. This warranty in lieu of all other warranties and conditions expressed or implied, including the warranties of merchantability and fitness for a particular purpose. ROCKWOOL Technical Insulation reserves the right to make necessary product changes at any time. Technical specifications are thus stated subject to change.

ROCKWOOL® Technical Insulation, ROCKWOOL®, SeaRox® and ProRox® are registered trademarks of ROCKWOOL International A/S and cannot be used without a prior written consent.

ROCKWOOL Technical Insulation www.rti.rockwool.com

PDS NO: PAA-00-2-001-ENG Issued: 08.06.2021 PROROX INDUSTRIAL INSULATION